

Branch	Status	TargetID	FacilityName	address	city	COUNTY_NAME	LATITUDE	LONGITUDE	NRCNumberOffFacilityOrSpill	FacilityOrVesselPOCName	FacilityOrVesselPOCNumber	wTypeOrFacility SpillOrVessel	assessmentDt	Assessment Type	Condition	rmwStatus	rmwPriority	comments	PhotoLink	Spill/Report Date	
Alpha	Refer to Other Agency (Open)	EPA-NRC-NRC-170909-06	/ / SANDIES CREEK			DE WITT	29.190887	-97.390186	1189439	MARGARET HUTSON	2813522705	Facility	9/10/2017	Phone Assessment	Damaged - No Discharge/Releases	Refer to Other Agency (Open)	Non-Emergency	This is an update of NRC report numbers 1188748 and 1188749. Response Manager report numbers EPA-NRC-NRC-170829-023 and EPA-NRC-NRC-170829-023, respectively. 36584 of oil and 7684 of produced water spilled into floodwaters of Sandies Creek, tributary of the Gadsden River, when the storage tanks on a well pad were displaced due to flood waters. No steam or residue remains in the area, all contents of the tanks have flowed downstream. Sandies Creek is approximately 2,400 ft from the well. THE CALLER IS REPORTING THAT HURRICANE HARVEY FLOODED A LIFT STATION. THE CALLER STATES THAT THERE WAS OIL IN MOTORS WITHIN THE LIFT STATION, BUT IT IS UNKNOWN IF A DISCHARGE OCCURRED.	No photos yet	8/29/2017	
Charlie	Assessment Required (Open)	EPA-NRC-NRC-170909-015	FLOOD WATERS		BEAUMONT	JEFFERSON	30.162603	-94.156516	1189466	TERRY CORBETT	9366760021	Facility	9/5/2017	Phone Assessment	Assessment Required (Open)	Assessment Required (Open)	Non-Emergency	A CALLER REPORTED DISCHARGES OF 12 BARRELS OF CRUDE OIL AND 143 BARRELS OF PRODUCE WATER INTO NAVASOTA RIVER FROM TWO SEPARATE STORAGE TANKS DUE TO THE HURRICANE HARVEY. THE CALLER STATED THAT THE CRUDE OIL TANK IS A STEEL SHELL WITH A 436 BARREL MAX CAPACITY TANK AND THE PRODUCE WATER TANK IS A FIBERGLASS SHELL WITH A 210 BARREL MAX CAPACITY TANK.	No photos yet	9/5/2017	
Bravo	Assessment Required (Open)	EPA-NRC-NRC-170909-025	NAVASOTA RIVER		HEMPSTEAD	Waller	30.525556	-96.120833	1189545	DOUGLAS WATNE	9793241036	Facility	9/10/2017	Phone Assessment	Assessment Required (Open)	Assessment Required (Open)	Non-Emergency	CALLER STATED DUE TO HURRICANE HARVEY, THE FLOOD WATERS COVERED FOUR LARGE ENGINES THAT CONTAINED A TOTAL OF 1500 GALLONS OF ENGINE OIL THAT ARE CONNECTED TO PUMPS. CALLER STATED THE AMOUNT OF ENGINE OIL RELEASED INTO THE FLOOD WATERS AND VEGETATION IS UNKNOWN AT THIS TIME. Assessment record added to capture branch info LUBE OIL DISCHARGED FROM APPROX. 50 GAS ENGINES THAT GOT PUSHED OUT OF THE PROCESSING FACILITY AS A RESULT OF HURRICANE HARVEY.	No photos yet	9/6/2017	
Charlie	Assessment Required (Open)	EPA-NRC-NRC-170909-031	PINE ISLAND BAYOU		BEAUMONT	JEFFERSON	30.178746	-94.18877	1189652	TERRY CORBETT	9366760021	Facility	9/10/2017	Phone Assessment	Assessment Required (Open)	Assessment Required (Open)	Non-Emergency	CALLER STATED DUE TO HURRICANE HARVEY, THE FLOOD WATERS COVERED FOUR LARGE ENGINES THAT CONTAINED A TOTAL OF 1500 GALLONS OF ENGINE OIL THAT ARE CONNECTED TO PUMPS. CALLER STATED THE AMOUNT OF ENGINE OIL RELEASED INTO THE FLOOD WATERS AND VEGETATION IS UNKNOWN AT THIS TIME. Assessment record added to capture branch info LUBE OIL DISCHARGED FROM APPROX. 50 GAS ENGINES THAT GOT PUSHED OUT OF THE PROCESSING FACILITY AS A RESULT OF HURRICANE HARVEY.	No photos yet	9/7/2017	
Charlie	Assessment Required (Open)	EPA-NRC-NRC-170909-011	DRAINAGE DITCH	1051 HWY 365	PORT ARTHUR	JEFFERSON	29.93124	-94.009558	1189638	RUBEN HERRERA	2817538367	Facility	9/6/2017	Phone Assessment	Assessment Required (Open)	Assessment Required (Open)	Non-Emergency	THIS IS AN UPDATE TO INCIDENT REPORT NUMBER 1188977 AND INCIDENT REPORT NUMBER 1189014. CALLER STATED THE SPILL HAS NOW REACHED A WATERWAY (DITCH NEXT TO THE FACILITY AND THE HOUSTON SHIP CHANNEL). PREVIOUS INCIDENT DESCRIPTION: ***** THIS IS A CORRECTION TO NRC REPORT # 1188977****. CORRECTION: THE AMOUNT OF RELEASED "GASOLINE TYPE PRODUCT" IS NOW 1000 BARRELS INSTEAD OF "UNKNOWN" ACCORDING TO THE GAS GAUGES. THE INCIDENT CAUSE IS "FLOOD" INSTEAD OF "UNKNOWN". ORIGINAL: THE RP IS REPORT#1	No photos yet	9/7/2017	
Charlie	Clean Up Completed (Closed)	UGG-NRC-NRC-170830-008	Noites	12220 Strang Road	La Porte	Harris	29.702209	-95.04255	1188502	Laura Burnett	713-412-5568	Facility	8/31/2017	Phone Assessment	Clean Up Completed (Closed)	Clean Up Completed (Closed)	Non-Emergency	2 Tanks destroyed. Total potential discharge of 40,000 gallons of crude glycerine and 80,000 gallons of wet methanol. Minimal cleanup done due to flood waters and excess mud. Projecting 2 month clean up. EDIT: CLEAN UP STILL IN PROGRESS (9-12-17). CHANGED DATE FROM 9-5-17 12:07 to 9-12-17 18:00	No photos yet	8/27/2012	
Bravo	Clean Up In Progress (Open)	EPA-NRC-NRC-170903-054		12901 American Petroleum rd	Houston	Harris	29.74138	-95.21034	1189206, 1189014, 1188977			Facility	9/8/2017	Phone Assessment	Spill	Clean Up In Progress (Open)	Non-Emergency	9/12/17 START Garcia and TCEQ Taylor. Could not locate transformer near given coordinates. No spill observed, no containers observed.	No photos yet	9/1/2017	
Bravo	Clean Up In Progress (Open)	UGG-NRC-NRC-170901-007	Channel Bio refinery Wesley McSwain	713-517-6331	13605 Industrial Rd	Houston	Harris	29.755024	-95.186583	1189015	Wesley McSwain	713-517-6331	Facility	9/12/2017	Phone Assessment	Damaged - Discharge/Releases	Clean Up In Progress (Open)	Non-Emergency	9/12/17 START Garcia and TCEQ Taylor did not find a transformer or spill near a storm drain.	No photos yet	9/1/2017
Alpha	No pollution Threat (Closed)	EPA-NRC-NRC-170909-032	POPANO BAY / ARANSAS BAY		139 SUNRISE DRIVE	ROCKPORT	ARANSAS	27.994987	-97.158483	1189454	BRIAN WHATLEY	3186173874	Facility	9/12/2017	Ground Assessment	No pollution Threat (Closed)	No pollution Threat (Closed)	Non-Emergency	9/12/17 START Garcia and TCEQ Taylor. Could not locate transformer near given coordinates. No spill observed, no containers observed.	No photos yet	9/5/2017
Alpha	No pollution Threat (Closed)	EPA-NRC-NRC-170909-036	STORM DRAIN / LITTLE BAY		1401 TEXAS HIGHWAY 35 NORTH	ROCKPORT	ARANSAS	27.99847	-97.102529	1189456	BRIAN WHATLEY	3186173874	Facility	9/12/2017	Ground Assessment	No pollution Threat (Closed)	No pollution Threat (Closed)	Non-Emergency	9/12/17 START Garcia and TCEQ Taylor. Could not locate transformer near given coordinates. No spill observed, no containers observed.	No photos yet	9/5/2017
Bravo	Clean Up Completed (Closed)	EPA-NRC-NRC-170831-027	CONTAINMENT AREA		1420 NORTH WITTER ROAD	PASADENA	HARRIS	29.725582	-95.203597	1188558/1188508		Facility	8/27/2017	Phone Assessment	Clean Up Completed (Closed)	Clean Up Completed (Closed)	Non-Emergency	[[THIS IS AN UPDATE TO REPORT 1188508]] UPDATED INFORMATION: THE ESTIMATED AMOUNT OF GASOLINE DISCHARGED IS 527 BARRELS INTO THE CONTAINMENT AREA. THE TANK IS BEING PUMPED OUT. ORIGINAL REPORT: CALLER IS REPORTING HEAVY RAIN CAUSED THE FLOATING ROOF OF A STORAGE TANK TO TILT OFF CENTER, WHICH RESULTED IN A DISCHARGE OF GASOLINE TO A CONTAINMENT DIKE. MATERIAL IS CONTAINED IN THE DIKE.	No photos yet	8/27/2012	
Bravo	Assessment Required (Open)	EPA-NRC-NRC-170909-019	HOUSTON SHIP CHANNEL		15602 JACINTO PORT BLVD	HOUSTON	HARRIS	29.756055	-95.105441	1189442		Facility	9/10/2017	Phone Assessment	Assessment Required (Open)	Assessment Required (Open)	Non-Emergency	CALLER IS MAKING A REPORT INVOLVING AN ABANDONED 55 GALLON DRUM THAT WAS FOUND FLOATING IN THE MIDDLE OF THE HOUSTON SHIP CHANNEL. CALLER STATES THERE DOES NOT APPEAR TO BE A MATERIAL RELEASE FROM THE DRUM AT THIS TIME. CALLER SUSPECTS THE ABANDONED DRUM IS A RESULT OF THE FLOODING DEBRIS FROM HURRICANE HARVEY.	No photos yet	9/5/2017	
Bravo	Clean Up In Progress (Open)	UGG-NRC-NRC-170830-015	Centerpoint Ricky Barger	409-682-6379	16301 West Montgomery Road	Houston	Harris	29.904603	-95.470246	1188647	Ricky Barger	409-682-6379	Facility	9/5/2017	Phone Assessment	Clean Up In Progress (Open)	Clean Up In Progress (Open)	Non-Emergency	Sub burning/venting to reduce changes of further spill. All oil contained in 10th containment. Could take 3-5 months.	No photos yet	8/28/2017
Bravo	No pollution Threat (Closed)	EPA-NRC-NRC-170909-013	FLOOD WATERS		17500 MARKET STREET	CHANNELVIEW	HARRIS	29.790395	-95.080543	1189450	MIKE ADAMS	5047908300	Facility	9/12/2017	Phone Assessment	No pollution Threat (Closed)	No pollution Threat (Closed)	Non-Emergency	CALLER REPORTS A DISCHARGE OF APPROXIMATELY TEN GALLONS OF DIESEL OIL ONTO THE GROUND WITH APPROXIMATELY 5 OR 6 GALLONS INTO THE FLOOD WATERS CAUSED BY A DAMAGED GENERATOR PEDESTAL AS A RESULT OF HURRICANE HARVEY. EDITED ON 9-12-17, CHANGED STATUS TO NO POLLUTION THREAT (NO VISIBLE OIL) CHANGED DATE FROM 9-5-17 15:30 TO 9-12-17 18:00	No photos yet	9/5/2017
Alpha	No pollution Threat (Closed)	EPA-NRC-NRC-170827-025	CONCRETE, ASPHALT, DIRT AND A DITCH		1802 NUCCES BAY BLVD.	CORPUS CHRISTI	NUCCES	27.806274	-97.42	1188516		Facility	9/13/2017	Ground Assessment	Operational	No pollution Threat (Closed)	No pollution Threat (Closed)	Non-Emergency	9/13/17 START Garcia and TCEQ Taylor contacted Mr. Galvan regarding private property spill into ditch. Mr Galvan stated that cleanup was conducted. No observed threat, no further action under ESP 10.	No photos yet	8/27/2017
Bravo	Discharge Identified Clean Up Not Initiated (Open)	EPA-NRC-NRC-170909-041	US OIL RECOVERY SUPERFUND		200 N. Richey Street	Pasadena	Harris	29.715233	-95.219604	1189806	ERIC PASTOR	[512]7509582	Facility	9/9/2017	Phone Assessment	Spill	Discharge Identified Clean Up Not Initiated (Open)	Non-Emergency	WATER TREATMENT FACILITY: STORM WATER (UNKNOWN AMOUNT), LIFT STATION. CALLER STATED THERE WAS A SPILL OF STORM WATER ON 08SEP2017 AT 1300 HOURS CST UNTIL1300 HOURS CST. CALLER STATED THIS WAS DUE TO AN OVERFLOW OF A LIFT STATION AT THE FORMER WASTE WATER TREATMENT PLANT FROM HEAVY RAINS IN THE AREA. CALLER STATED THEY STOPPED THE OVERFLOW.	No photos yet	9/9/2017
Bravo	Discharge Identified Clean Up Not Initiated (Open)	EPA-NRC-NRC-170909-040	US OIL RECOVERY SUPERFUND		200 RICHEY STREET	PASADENA	HARRIS	29.715233	-95.219604	1189805	ERIC PASTOR	[512]7509582	Facility	9/9/2017	Phone Assessment	Spill	Discharge Identified Clean Up Not Initiated (Open)	Non-Emergency	WATER TREATMENT FACILITY: STORM WATER (UNKNOWN AMOUNT), LIFT STATION. CALLER STATED THERE WAS A SPILL OF STORM WATER ON 08SEP2017 AT 1300 HOURS CST UNTIL1300 HOURS CST. CALLER STATED THIS WAS DUE TO AN OVERFLOW OF A LIFT STATION AT THE FORMER WASTE WATER TREATMENT PLANT FROM HEAVY RAINS IN THE AREA. CALLER STATED THEY STOPPED THE OVERFLOW.	No photos yet	9/9/2017
Bravo	Clean Up Completed (Closed)	UGG-NRC-NRC-170830-009	Blue Cube Operations Bonnie Martinez	979-235-9031	2301 Brazosport Blvd	Freeport	Brazoria	28.98632	-95.380061	1188629	Bonnie Martinez	979-235-9031	Facility	9/5/2017	Phone Assessment	No Damage	Clean Up Completed (Closed)	Non-Emergency	Source secured from air release. AN ESTIMATED 23.5 BARRELS OF GASOLINE DISCHARGED FROM A STORAGE TANK. DUE TO HIGH WATER ON THE ROOF OF THE TANK (CAUSE BY HEAVY PRECIPITATION FROM HURRICANE HARVEY), ALL PRODUCT IS CONTAINED ON RAINWATER IN SECONDARY CONTAINMENT. ALL PRODUCT RETRIEVED. CLEAN UP COMPLETE.	No photos yet	8/28/2017
Bravo	Clean Up Completed (Closed)	EPA-NRC-NRC-170831-011	PHILLIPS / SECONDARY CONTAINMENT-TANK DIKE		233 N. PHILLIPS ROAD	PASADENA	HARRIS	29.714709	-95.175588	1188880	Diane Otto	832-514-5579	Facility	8/31/2017	Ground Assessment	Damaged - Discharge/Releases	Clean Up Completed (Closed)	Non-Emergency	CALLER REPORTS A DISCHARGE OF APPROXIMATELY TEN GALLONS OF DIESEL OIL ONTO THE GROUND WITH APPROXIMATELY 5 OR 6 GALLONS INTO THE FLOOD WATERS CAUSED BY A DAMAGED GENERATOR PEDESTAL AS A RESULT OF HURRICANE HARVEY. EDITED ON 9-12-17, CHANGED STATUS TO NO POLLUTION THREAT (NO VISIBLE OIL) CHANGED DATE FROM 9-5-17 15:30 TO 9-12-17 18:00	No photos yet	8/31/2017
Bravo	Clean Up Completed (Closed)	UGG-NRC-NRC-170830-007	Exxon Mobil Baytown		2800 Decker Dr	Baytown	Harris	29.756338	-94.991453	1188500	Diane Otto	832-514-5579	Facility	8/31/2017	Phone Assessment	Spill	Clean Up Completed (Closed)	Non-Emergency	PRODUCT RETRIEVED. CLEAN UP COMPLETE.	No photos yet	8/27/2017
Charlie	Assessment Required (Open)	EPA-NRC-NRC-170831-012	SOIL		325 PINE STREET	PORT NECHES	JEFFERSON	29.976162	-93.934714	1188967		Facility	8/31/2017	Phone Assessment	Assessment Required (Open)	Assessment Required (Open)	Non-Emergency	DUE TO UNKNOWN CAUSES.	No photos yet	8/31/2017	
Bravo	Clean Up Completed (Closed)	UGG-NRC-NRC-170830-016	Exxon Mobil Kelly Davis	832-262-3887	3525 Decker Dr	Baytown	Harris	29.746619	-95.013817	1188534	Kelly Davis	832-262-3887	Facility	8/31/2017	Phone Assessment	Clean Up Completed (Closed)	Clean Up Completed (Closed)	Non-Emergency	CALLER STATED THAT DUE TO HURRICANE HARVEY THERE WAS A SPILL OF INDUSTRIAL WASTE WATER SURFACTANTS AT THE CHEMICAL FACILITY.	No photos yet	8/27/2017
Bravo	Assessment Required (Open)	EPA-NRC-NRC-170829-033	FLOOD CONTROL		3892 US HIGHWAY 90W	DAYTON	LIBERTY	30.000096	-94.953086	1188696		Facility	8/29/2017	Phone Assessment	Assessment Required (Open)	Assessment Required (Open)	Non-Emergency	CALLER STATED THAT DUE TO HURRICANE HARVEY THERE WAS A SPILL OF INDUSTRIAL WASTE WATER SURFACTANTS AT THE CHEMICAL FACILITY.	No photos yet	8/29/2017	
Bravo	Assessment Required (Open)	EPA-NRC-NRC-170831-035	FLOOD WATERS		480 CTY ROAD 167	GEORGETOWN	Williamson	30.665913	-97.572552	1188934		Facility	8/31/2017	Phone Assessment	Assessment Required (Open)	Assessment Required (Open)	Non-Emergency	CALLER STATED THAT FLOOD WATERS FROM HURRICANE HARVEY FLOODED VARIOUS TOTES, DRUMS, AND ABOVE GROUND STORAGE TANKS ON THE PROPERTY, CAUSING THE RELEASE OF OF DIESEL FUEL AND GASOLINE TO THE FLOOD WATERS.	No photos yet	8/31/2017	
Bravo	No pollution Threat (Closed)	EPA-NRC-NRC-170829-039	FLOOD WATERS		500 W OF 26780 FM 2990	SPELNDORA	MONTGOMERY	30.261955	-95.085866	1188753		Facility	8/29/2017	Phone Assessment	No pollution Threat (Closed)	No pollution Threat (Closed)	Non-Emergency	CALLER IS REPORTING THAT DUE TO THE HURRICANE, A TRANSFORMER FELL FROM A POLE AND DISCHARGED NON-PCB TRANSFORMER OIL ON THE FLOOD WATERS.	No photos yet	8/29/2017	
Charlie	Assessment Required (Open)	EPA-NRC-NRC-170829-063	STORM DRAIN/GROUND		6150 MIRE STREET	GROVES	JEFFERSON	29.93887	-93.908778	1188712		Facility	8/29/2017	Phone Assessment	Assessment Required (Open)	Assessment Required (Open)	Non-Emergency	CALLER IS REPORTING A POLE MOUNTED TRANSFORMER WAS KNOCKED DOWN BY HURRICANE HARVEY, RESULTING IN A DISCHARGE OF TRANSFORMER OIL. IT IS UNKNOWN IF THE OIL CONTAINED PCB'S.	No photos yet	8/29/2017	
Bravo	Clean Up Completed (Closed)	EPA-NRC-NRC-170831-026	Shell (Galena Park)		780 Clinton dr	Galena Park	Harris	29.7317	-95.22234	1188953		Facility	8/31/2017	Phone Assessment	Clean Up Completed (Closed)	Clean Up Completed (Closed)	Non-Emergency	CALLER STATED THAT LUBRICATING OIL AND REFINED BASE OIL DISCHARGED ONTO CONCRETE, SOIL, AND GRAVEL DUE TO FLOODING FROM HURRICANE HARVEY OVERWHELMING THE OILY WATER SEPARATOR.	No photos yet	8/31/2017	
Bravo	No pollution Threat (Closed)	UGG-NRC-NRC-170902-018	Nexo Solutions		8901 Galveston Rd	Houston		29.633514	-95.204775			Facility	9/2/2017	Phone Assessment	Damaged - No Discharge/Releases	No pollution Threat (Closed)	Non-Emergency	RP sent out oil samples for testing, awaiting results. Fire System triggered fire system to run and seal ruptured. approx 127 gallons spilled awaiting samples.	No photos yet	9/2/2017	
Bravo	Clean Up In Progress (Open)	UGG-NRC-NRC-170831-007	Enterprise Products Robert Burkhalter	281-887-2640	901 Clinton Drive	Galena Park	Harris	29.907623	-95.554639	1188947	Robert Burkhalter	281-887-2640	Facility	8/31/2017	Ground Assessment	Damaged - Discharge/Releases	Clean Up In Progress (Open)	Emergency	200 Barrel crude oil discharged to containment dyle wall within a tank farm at 901 Clinton Dr, Galena Park 77547	No photos yet	8/31/2017
Bravo	Clean Up Completed (Closed)	UGG-NRC-NRC-170830-002	Kinder Morgan Pasadena John Powe	281-961-3368	906 Clinton Dr	Galena Park	Harris	29.720639	-95.225533	1188488	John Powe	281-961-3368	Facility	9/1/2017	Phone Assessment	Spill	Clean Up Completed (Closed)	Non-Emergency	9/12/17 START Garcia and TCEQ conducted HazMat and found replaced transformers and pole at facility. No visible spill or containers, only stagnant water. possible spill occurred from transformer with PCBs as reported in initial NRC Report. Referring to TRRC.	No photos yet	8/27/2017
Alpha	Refer to Other Agency (Closed)	EPA-NRC-NRC-170909-014	FLOOD WATERS		AUSTWELL FISH FARM	AUSTWELL	REFUGIO	28.364149	-96.814944	1189462	BRIAN WHATLEY	3186173874	Facility	9/12/2017	Ground Assessment	Damaged - No Discharge/Releases	Refer to Other Agency (Closed)	Non-Emergency	CALLER IS REPORTING THAT DUE TO THE HURRICANE, A STORAGE TANK ROOF TILTED AND MATERIAL RELEASED FROM THE ROOF DRAIN INTO THE SECONDARY CONTAINMENT AREA.	No photos yet	9/5/2017
Bravo	Assessment Required (Open)	EPA-NRC-NRC-170902-060	SECONDARY CONTAINMENT		SEE LAT/LONG	WEBSTER	HARRIS	29.521667	-95.106111	1189169		Facility	9/2/2017	Phone Assessment	Assessment Required (Open)	Assessment Required (Open)	Non-Emergency		No photos yet	9/2/2017	